



May 2, 2014

Mr. Carl Perry
E-Z Treat Systems, LLC
1700 Davis St
Rocky Mount, NC 27803

Dear Dave,

I am writing to provide a status of the NSF Certification for the E-Z Treat EZ 600 Wastewater Treatment system under NSF/ANSI Standard 40.

The E-Z 600 Treatment system has successfully passed the performance testing and evaluation requirements of the Standard, achieving a Class I effluent quality.

Remaining requirements needed to achieve NSF certification include the following:

- Testing and evaluation of the control panel; Sample J-00138777
- Review of the product literature; and
- Initial audit of the E-Z Treat manufacturing facility.

Once the above are completed and meet the requirements of NSF/ANSI Standards 40, I will recommend the EZ 600 treatment system be added to the NSF/ANSI Standard 40 Official Listing.

Please contact me with any questions you may have.

Sincerely,

A handwritten signature in cursive script that reads "Sharon Steiner".

Sharon Steiner
Business Unit Manager
Wastewater Treatment Unit Program

734-827-6846 (Voice)
734-827-7790 (Fax)
steiner@nsf.org (E-mail)

cc: corporate correspondence (C00173848)