


- Other approved recirculation options:
- ATS-GRD-4/1
 - ATS-GRD-80/20
 - ATS-GRD-100/80/20-N
 - ATS-PRD-4/1

Other approved tankage option:
 A single two compartment tank with septic tank effluent filter and access on the outlet of the septic compartment on the baffle wall. First (septic) compartment to be at least twice daily flow and second (as dosing/recirculation) compartment to be at least equal to the daily flow. STEP system and recirculation must be in the second compartment.



	GRAVITY LINES
	PRESSURE LINES
	QUANICS COMPONENTS
	NDN-QUANICS COMPONENTS
	SYSTEM FOOTPRINT

Quantics Contacts - Technical		AutoCad Drawings	
Brian Borders, R.S. 502-992-8274 bborders@quantics.net	Eric Shields 502-992-8235 eshields@quantics.net	Tom Jenkins 502-992-8216 tjenkins@quantics.net	
Tom Peely, P.G., R.L.E.H.S. 502-992-8238 tpeely@quantics.net	Kevin Sherman, P.E., Ph.D. 502-751-7298 ksherman@quantics.net		

CUSTOM DRAWINGS AVAILABLE
 Take advantage of Quantics' custom drawing services.
 We offer conceptual drawings to adding wastewater systems to your development.

Product(s) covered by one or more U.S. and/or International patents. Other U.S. and International patents may be pending.

SCALE	NAME	DATE
GPD	Drawn By	06-29-09
650	Technical Approval	06-29-09
	Engineer Approval	

P.O. Box 1520
 Chestwood KY 40014
877-QUANICS
 www.quantics.net