



Other approved tankage option:

Two tanks in series instead of two compartment tank with the effluent filter on the outlet pipe of the first tank (septic tank) and the recirculation device on the inlet access opening of the second tank (ATS dosing tank).
 If this option is used the septic tank must be at least twice the daily flow and the ATS dosing tank must be at least equal to the daily flow.

Other approved options for recirculation:

- ATS-GRD-4/1
- ATS-GRD-80/20
- ATS-GRD-100/80/20
- ATS-PRD-4/1

750 gallons per day
 138ft³ of natural coir media
 543 gpd/ft³ hydraulic loading rate
 Eight 170 degrees spray nozzles

Quantics Contacts - Technical		AutoCad Drawings	
Brian Borders, R.S. 502-492-4274 bborders@quantics.net	Eric Shields 502-492-4235 eshields@quantics.net	Tom Jenkins 502-492-4216 Tjenkins@quantics.net	
Tom Petty, P.E., R.E.H.S. 502-492-4236 tpetty@quantics.net	Kevin Sherman, P.E., Ph.D. 502-751-7298 ksherman@quantics.net		

CUSTOM DRAWINGS AVAILABLE

Take advantage of Quantics' custom drawing services. We offer conceptual drawings to adding wastewater systems to your development.

Product(s) covered by one or more U.S. and/or International patents. Other U.S. and International patents may be pending.

SCALE	NAME	DATE
GPD	TNU	05-20-09
750	KS	05-20-09

	GRAVITY LINES
	PRESSURE LINES
	QUANICS COMPONENTS
	NDN-QUANICS COMPONENTS
	QUANICS TEXT



P.O. Box 1520
 Crestwood KY 40014
877-QUANICS
www.quantics.net