



**COMMONWEALTH OF VIRGINIA  
VIRGINIA DEPARTMENT OF HEALTH**

August 10, 2010

Ben Berteau  
Science & Government Affairs  
Infiltrator Systems, Inc.  
P.O. Box 768  
Old Saybrook, CT 06475

Re: Approval of Infiltrator Systems, Inc., Dosing/Holding Tanks

Dear Mr. Berteau:

The following Infiltrator Systems, Inc., HDPE tanks substantially comply with the structural requirements of the *Sewage Handling and Disposal Regulations*:

300-gallon dosing/holding tank, identified as TW-300  
375-gallon dosing/holding tank, identified as TW-375  
500-gallon dosing/holding tank, identified as TW-500  
1,060-gallon dosing/holding tank, identified as TW-900  
1,217-gallon dosing/holding tank, identified as TW-1050  
1,452-gallon dosing/holding tank, identified as TW-1250  
1,766-gallon dosing/holding tank, identified as TW-1500

Designers are responsible for complying with the specific regulatory requirements for dosing and holding tanks as applicable to their site-specific designs.

Approval of these products does not constitute endorsement for use. This approval letter is supplemental to the August 6 and August 27, 2008 letters regarding approval of TW-series tanks.

Please do not hesitate to contact me at (804) 387-5045 if you have any questions regarding this matter.

Sincerely,

A handwritten signature in blue ink that reads "C. Kemper Loyd".

C. Kemper Loyd, P.E.  
Technical Services Engineer  
OEHS – Wastewater Engineering  
131 Walker Street  
Lexington, Virginia 24450

Cc: Allen Knapp, VDH-OEHS