

January 20, 1993

GMP # 16

MEMORANDUM

TO: District Directors
Environmental Health Managers
Environmental Health Supervisors
Contract Soil Scientists

FROM: David Effert, Technical Services Chief
Division of Onsite Sewage and Water Services

SUBJECT: Use of CAPROLAN-RC Nylon Fibers in Place of Welded
Fabric in Precast Septic Tanks

CAPROLAN-RC nylon fibers has been approved for use in pre-cast septic tanks as an alternative to the 6 by 6 inch mesh, #12 welded wire fabric currently specified in the Suggested Design and Construction Criteria for Prestressed and Poured in Place Concrete Septic Tanks of the Sewage Handling and Disposal Regulations. This product does not replace or substitute for the use of reinforcing rods, when reinforcing rods are required.

Approval of this product is contingent upon its proper use as specified in the manufacturer's literature. A copy of the literature is attached.

DDE/

Attachment

cc: Division of Onsite Sewage and Water Staff

GMP # 16
Sewage - Septic Tank - Materials - Approvals