

October 4, 1993

GMP #38

MEMORANDUM

TO: District Directors
Environmental Health Managers
Environmental Health Supervisors
Environmental Health Specialists

FROM: David Effert, Technical Services Chief
Division of Onsite Sewage and Water Services

SUBJECT: Approval of the United Baffle and Gas Deflector
Onsite - Product Approval - Septic Tank

The United Baffle without the United Gas Deflector, has been approved for use as an inlet structure under Section 4.16.C.3.a and 4.16.C.3.b of the Sewage Handling and Disposal Regulations. The United Baffle with or without the United Gas Deflector has been approved for use as an outlet structure under Section 4.16.C.3.a and 4.16.C.3.b of the Sewage Handling and Disposal Regulations. These products are manufactured by United Concrete Products, Inc. of Yalesville, CT. The manufacturer's recommendations for use must be followed. When installed, the structure's length must comply with Section 4.16.C.3.a of the regulations. A copy of the manufacture's literature is attached.

Approval of the product does not constitute endorsement for use. Please report any field problems that you may have with the product to me at (804) 786-1750.

DDE/

ATTACHMENT

pc: Office of Environmental Health Services Staff
Cal Sawyer, Ph.D., P.E.
United Concrete Products
Robert F. Adams

GMP #38

Onsite - Product Approval - Septic Tank