

FECAL INCIDENT RESPONSE

<u>FORMED STOOLS</u>	<u>DIARRHEA</u>
1 CLOSE POOL: EVACUATE <u>ALL</u> PATRONS FROM POOLS ON SAME FILTER.	1 CLOSE POOL: EVACUATE <u>ALL</u> PATRONS FROM POOLS ON SAME FILTER.
2 REMOVE AS MUCH FECAL MATTER AS POSSIBLE. (NET OR SCOOP) (VACUUMING <u>NOT</u> RECOMMENDED)	2 REMOVE AS MUCH FECAL MATTER AS POSSIBLE. (NET/SCOOP) (VACUUMING <u>NOT</u> RECOMMENDED)
3 RAISE CHLORINE TO BETWEEN 2.0 – 3.0 PPM, PH 7.2 - 7.5	3 RAISE CHLORINE TO 20.0 PPM, PH 7.2 - 7.5
4 MAINTAIN THESE CHEMICAL LEVELS FOR 30 MINUTES.	4 MAINTAIN CHLORINE 20.0 PPM, PH 7.2 – 7.5 FOR A MINIMUM OF 12.75 HOURS.
5 AFTER 30 MINUTES: VERIFY AND RECORD CHLORINE AND PH CONCENTRATION LEVELS.	5 ENSURE FILTRATION SYSTEM IS OPERATING WHILE POOL REACHES AND MAINTAINS CHLORINE DISINFECTION.
6 *REOPEN POOL	6 BACKWASH FILTER THOROUGHLY AFTER THE 12.75 HOURS.
7 DOCUMENT INCIDENT: DATE, BEGINNING & END TIMES, TYPE, STEPS TAKEN, LENGTH OF TIME CHLORINE ? 2.0 PPM. *NOTIFY HEALTH DEPT*	7 AFTER 12.75 HOURS: RETURN CHLORINE LEVEL TO NORMAL LEVEL (1.0 – 3.0 PPM). VERIFY AND RECORD CHLORINE AND PH CONCENTRATION LEVELS.
NOTE: VOMIT INCIDENTS ARE TO BE TREATED IN THE SAME MANNER AS A FORMED STOOL INCIDENT!	8 *REOPEN POOL
	9 DOCUMENT INCIDENT: DATE, BEGINNING & END TIMES, TYPE, STEPS TAKEN, LENGTH OF TIME CHLORINE @ 20.0 PPM. *NOTIFY HEALTH DEPT*

**CONTACT THE PORTSMOUTH HEALTH DEPARTMENT'S
ENVIRONMENTAL HEALTH SERVICES
FOR ALL POOL QUESTIONS
(757) 393-8585 EXT. 8585**