

August 6, 1992

GMP #3

Mr. Latt Moretz
Bethlehem Mfg. Co., Inc.
Route 16, Box 1648
Hickory, North Carolina 28601

Dear Mr. Moretz:

To confirm our conversation yesterday, I have reviewed the plans for distribution box forms VA-001-D and VA-002-D. Plan VA-001-D is for a square 7 outlet box and Plan VA-002-D is for a rectangular 11 outlet box. The plans appear to comply with the minimum requirements of the Sewage Handling and Disposal Regulations.

Also, please note that this is an approval of the forms only. The contractor still must use a proper material (concrete, 3000 psi) and the box must be properly installed.

If you have any questions, please contact me.

Sincerely,

Gary L. Hagy
Assistant Director
Division of Onsite Sewage
and Water Services

Attachment

pc: Environmental Health Managers
Division of Onsite Sewage and Water Services Staff

GMP #3
Sewage - Onsite - Approvals