



# COMMONWEALTH of VIRGINIA

*Department of Health*

P O BOX 2448

Richmond, VA 23218

Marissa Levine, MD, MPH, FAAFP  
State Health Commissioner

TTY 7-1-1 OR  
1-800-828-1120

May 20, 2016

Damon Hunley  
Southeast Regional Manager Onsite  
Advanced Drainage Systems, Inc.  
4640 Trueman Blvd.  
Hilliard, OH 43026

Re: Authorization Pursuant to GMP 2016-01  
Advanced Drainage Systems, Inc. (ADS) Septic Stack 9-pipe, 11-pipe, and 13-pipe Gravelless Dispersal Systems

Dear Mr. Hunley:

The Virginia Department of Health engineering staff has completed its review of the above referenced products for authorization under Guidance Memorandum and Policy (GMP) 2016-01.

Based upon the information supplied by Advanced Drainage Systems, Inc. (ADS), the Septic Stack 9-pipe, 11-pipe, and 13-pipe gravelless dispersal systems substantially comply with the requirements set forth in the referenced policy and are hereby authorized for use as provided by the provisions of this policy. It is noted that only H10 traffic load verification was provided, so the units' use is limited to non-traffic areas.

If you have any questions, please contact Stephen Elgin, P.E., Technical Services Engineer at 434-477-5918.

Sincerely,

A handwritten signature in black ink that reads "Marcia J. Degen".

Marcia J. Degen, Ph.D, P.E.

Environmental Technical Services Administrator

cc: Lance Gregory, Environmental Health Coordinator  
Stephen Elgin, P.E., Technical Services Engineer