

March 21, 1995

GMP # 65

Mr. Latt Moretz
Bethlehem Manufacturing Co., Inc.
Route 16, Box 1648
Hickory, North Carolina 28601

Dear Mr. Moretz:

I have reviewed the plans for septic tank forms VA012 and VA013. Plan VA012 is for an approximately 1,264 gallon septic tank and Plan VA013 is for an approximately 1,028 gallon septic tank. Forms VA012 and VA013 are for Hanover Concrete Corporation, 9129 Fenway Drive, Mechanicsville, Virginia 23111. The plan numbers will be incorporated into the tank form. The plans appear to comply with the minimum requirements of the Sewage Handling and Disposal Regulations.

Also, please note that this is an approval of the forms only. The contractor still must use a proper material, i.e., a minimum of 3,000 psi concrete and the appropriate reinforcing materials. The tanks must also be properly installed.

If you have any questions, please contact me.

Sincerely,

Gary L. Hagy
Assistant Director
Division of Onsite Sewage
and Water Services

Attachment

pc: Environmental Health Project Managers
Environmental Health Managers
Division of Onsite Sewage and Water Services Staff

GMP # 65
Sewage - Onsite - Approvals