

**Testing Sites and *Legionella* Environmental Testing Results,  
Chesterfield County, Updated 08/07/2019**

Sample ID	Collection Date	Source	Location Address	Sample Description	Multiplex Polymerase Chain Reaction (PCR) Results	Culture
VA19-1-086	7/24/2019	bulk	Greenfield Elementary 10751 Savoy Rd Richmond, VA 23235	CT bleed valve in mechanical room	<i>Legionella pneumophila</i> , serogroup 1	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-087	7/24/2019	bulk		EvapCo CT 2, basin	<i>Legionella pneumophila</i> , serogroup 1	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-088	7/24/2019	bulk		EvapCo CT 1, basin	<i>Legionella pneumophila</i> , serogroup 1	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-089	7/24/2019	swab		EvapCo CT 1, left side	<i>Legionella pneumophila</i> , serogroup 1	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-090	7/24/2019	swab		EvapCo CT 2, far right	<i>Legionella pneumophila</i> , serogroup 1	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-091	7/24/2019	bulk	Midlothian Middle School 13501 Midlothian Turnpike, Midlothian, VA 23113	BAC CT equalization line, post flush	<i>Legionella</i> species, possible inhibition	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-092	7/24/2019	bulk		BAC CT equalization line, 1st draw w/ sediment	<i>Legionella</i> species, possible inhibition	no growth
VA19-1-093	7/24/2019	swab		BAC CT 2, Face A side panel	<i>Legionella</i> species, possible inhibition	<i>Legionella pneumophila</i> , serogroup 1 and <i>Legionella</i> species, identification pending
VA19-1-094	7/24/2019	swab		BAC CT 1, Face D side panel	inhibition	<i>Legionella</i> species, identification pending
VA19-1-004	7/25/2019	bulk	Johnston-Willis Hospital 1401 Johnston Willis Dr, North Chesterfield, VA 23235	CT 2, basin	<i>Legionella</i> species	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-005	7/25/2019	swab		CT 2, biofilm swab of waterline	<i>Legionella</i> species	no growth
VA19-1-006	7/25/2019	bulk		Tower tech 1, remote sample from drain line (condensed water pump 1)	<i>Legionella</i> species	no growth
VA19-1-008	7/25/2019	bulk		CT 1, basin	<i>Legionella</i> species (indeterminate for <i>Legionella pneumophila</i> )	no growth
VA19-1-009	7/25/2019	swab		CT 1	<i>Legionella</i> species, possible inhibition	no growth
VA19-1-010	7/25/2019	swab		CT 3 (standalone small basin)	<i>Legionella</i> species	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-011	7/25/2019	bulk		CT 3 (standalone small basin)	<i>Legionella pneumophila</i> , serogroup 1	pending
VA19-1-026	7/26/2019	swab		Aleris 1801 Reymet Rd, Richmond, VA 23237	CT basin (interior)	<i>Legionella</i> species, possible inhibition
VA19-1-027	7/26/2019	bulk	CT basin (interior)		negative, inhibition	pending

Sample ID	Collection Date	Source	Location Address	Sample Description	Multiplex Polymerase Chain Reaction (PCR) Results	Culture
VA19-1-022	7/26/2019	bulk	Kaiser Aluminum 1901 Reymet Rd, Richmond, VA 23237	CT 3 (wood), basin	<i>Legionella pneumophila</i>	pending
VA19-1-023	7/26/2019	swab		CT 3 (wood), wooden side slats	<i>Legionella</i> species	pending
VA19-1-024	7/26/2019	bulk		CT 1	<i>Legionella</i> species	pending
VA19-1-025	7/26/2019	swab		CT 1	negative, inhibition	pending
VA19-1-082	7/25/2019	swab	Reynolds 2001 Reymet Rd, North Chesterfield, VA 23237	CT (left) inside basin	<i>Legionella</i> species	pending
VA19-1-083	7/25/2019	bulk		CT (left) inside basin	<i>Legionella pneumophila</i> , serogroup 1	pending
VA19-1-001	7/25/2019	bulk	Falling Creek Middle School 4724 Hopkins Rd, North Chesterfield, VA 23234	Evapco CT, basin (not active)	<i>Legionella</i> species	no growth
VA19-1-002	7/25/2019	swab		Evapco CT, basin (not active)	<i>Legionella</i> species	<i>Legionella pneumophila</i> , serogroup 1
VA19-1-003	7/25/2019	bulk	Meadowbrook High School 4901 Cogbill Rd, North Chesterfield, VA 23234	EvapCo CT, basin drain line	Indeterminate for <i>Legionella</i> species	no growth
VA19-1-098	7/23/2019	swab		BAC CT, east side panel	negative	no growth
VA19-1-099	7/23/2019	swab		BAC CT, east side panel	negative	no growth
VA19-1-100	7/23/2019	bulk		CT bleed valve in mechanical room	negative	no growth
VA19-1-095	7/23/2019	bulk	Hopkins Road Elementary School 6000 Hopkins Rd, North Chesterfield, VA 23234	Small EvapCo CT, basin	<i>Legionella</i> species	no growth
VA19-1-096	7/23/2019	swab		Small EvapCo CT, north side panel	inhibition	blue-white spp., identification pending
VA19-1-097	7/23/2019	bulk		Large BAC CT	negative	no growth
VA19-1-018	7/26/2019	bulk	US Marine Corps Services Center 6000 Strathmore Rd, North Chesterfield, VA 23234	Evapco CT, bleed valve in mechanical room	<i>Legionella</i> species	pending
VA19-1-084	7/25/2019	bulk	Richmond Ice Zone 636 Johnston Willis Dr, North Chesterfield, VA 23236	BAC CT, remote basin in mechanical room	<i>Legionella pneumophila</i> , serogroup 1	no growth
VA19-1-085	7/25/2019	swab		BAC CT, remote basin in mechanical room	<i>Legionella pneumophila</i>	<i>Legionella pneumophila</i> , serogroup 1

Sample ID	Collection Date	Source	Location Address	Sample Description	Multiplex Polymerase Chain Reaction (PCR) Results	Culture
VA19-1-012	7/26/2019	bulk	US Defense Supply Center 8000 Jefferson Davis Hwy, Richmond, VA 23297	National Guard Building, SPX Marley CT, basin water	<i>Legionella pneumophila</i> , serogroup 1	pending
VA19-1-013	7/26/2019	swab		National Guard Building, SPX Marley CT, biofilm swab of waterline	<i>Legionella</i> species	pending
VA19-1-014	7/26/2019	swab		Building 46, BAC CT 1 (backup), biofilm swab of waterline	negative	pending
VA19-1-015	7/26/2019	bulk		Building 46, BAC CT 2 (backup), basin water	negative	pending
VA19-1-016	7/26/2019	bulk		Building 34, BAC CT, blow down	negative	pending
VA19-1-017	7/26/2019	bulk		Building 34, BAC CT, basin drain line	negative, possible inhibition	pending

\*Note: All environmental testing was conducted by the Centers for Disease Control and Prevention (CDC) in Atlanta, Georgia. Additional testing is underway, and some results are pending as of 8/7/2019.