

September 4, 1992

GMP# 5

MEMORANDUM

TO: District Directors  
Environmental Health Managers  
Environmental Health Supervisors

FROM: Dave Effert, Technical Services Chief  
Division of Onsite Sewage and Water Services

SUBJECT: Use of SDR 35 Pipe in Building Sewers

Effective immediately, Poly Vinyl Chloride (PVC) gravity drain and sewer pipe and fittings manufactured to meet a minimum Standard Dimension Ratio (SDR) of 35 and the physical requirements of ASTM D-3034 shall be acceptable for use as building sewer pipe under Section 4.10 of the Sewage Handling and Disposal Regulations.

Please maintain a copy of this memo in your GMP manual and in the Sewage Handling and Disposal Regulations Implementation Manual. Also, make sure that all environmental health specialists working in the sewage program receive a copy of this GMP.

If you have any questions, please do not hesitate to call me at (804) 786-1750.

pc: Division of Onsite Sewage and Water Services

GMP# 5  
Sewage - Soil Absorption - Approvals