

September 30, 1992

**GMP #6**

Mr. Latt Moretz  
Bethlehem Mfg. Co., Inc.  
Route 16, Box 1648  
Hickory, North Carolina 28601

Dear Mr. Moretz:

I have reviewed the plans for septic tank forms VA-006 and VA-007. Plan VA-006 is for an approximately 1,043 gallon septic tank and Plan VA-007 is for an approximately 1,293 gallon septic tank. These forms are for Hampton Roads Presstress, Inc., of Franklin, Virginia. The plan numbers will be incorporated into the tank form. The plans appear to comply with the minimum requirements of the Sewage Handling and Disposal Regulations.

Also, please note that this is an approval of the forms only. The contractor still must use a proper material, i.e., a minimum of 3,000 psi concrete and the appropriate reinforcing materials. The tanks must also be properly installed.

If you have any questions, please contact me.

Sincerely,

Gary L. Hagy  
Assistant Director  
Division of Onsite Sewage  
and Water Services

Attachment

pc: Environmental Health Project Managers  
Environmental Health Managers  
Division of Onsite Sewage and Water Services Staff

**GMP #6**  
**Sewage - Onsite - Approvals**