

November 3, 1992

GMP #10

Mr. Latt Moretz
Bethlehem Mfg. Co., Inc.
Route 16, Box 1648
Hickory, North Carolina 28601

Dear Mr. Moretz:

I have reviewed the plans for septic tank forms VA008, VA009 and VA010. Plan VA008 is for an approximately 1,028 gallon septic tank, Plan VA009 is for an approximately 1,264 gallon septic tank and Plan VA010 is for an approximately 1,000 gallon septic tank. Forms VA008 and VA009 are for Nuckols Enterprises, Inc., of Manakin-Sabot, Virginia. Form VA010 is for Hampton Roads Prestress, Inc., of Franklin, Virginia. The plan numbers will be incorporated into the tank form. The plans appear to comply with the minimum requirements of the Sewage Handling and Disposal Regulations.

Also, please note that this is an approval of the forms only. The contractor still must use a proper material, i.e., a minimum of 3,000 psi concrete and the appropriate reinforcing materials. The tanks must also be properly installed.

If you have any questions, please contact me.

Sincerely,

Gary L. Hagy
Assistant Director
Division of Onsite Sewage
and Water Services

Attachment

pc: Environmental Health Project Managers
Environmental Health Managers
Division of Onsite Sewage and Water Services Staff

GMP #10 - Sewage - Onsite - Approvals