

May 11, 1993

GMP #26

MEMORANDUM

TO: District Directors
Environmental Health Managers
Environmental Health Supervisors
Environmental Health Specialists

FROM: Gary L. Hagy, Assistant Director
Division of Onsite Sewage and Water Services

SUBJECT: Approval of Septic Tank Forms
Onsite - Product Approval - Septic Tanks

The attached letter is an approval of a septic tank form proposed by Bethlehem Manufacturing Co., Inc. of Hickory, North Carolina. Please add this memo and the attached letter to your GMP Manual as GMP #26.

Attachment

pc: Office of Environmental Health Services Staff

GMP #26

Onsite - Product Approval - Septic Tanks

May 11, 1993

GMP #26

Mr. Latt Moretz
Bethlehem Mfg. Co., Inc.
Route 16, Box 1648
Hickory, North Carolina 28601

Dear Mr. Moretz:

I have reviewed the plans for septic tank form VA011. Plan VA011 is for an approximately 1,005 gallon septic tank. Form VA011 is for W. C. Newman, Co., Inc., of Farmville, Virginia. The plan numbers will be incorporated into the tank form. The plans appear to comply with the minimum requirements of the Sewage Handling and Disposal Regulations.

Also, please note that this is an approval of the forms only. The contractor still must use a proper material, i.e., a minimum of 3,000 psi concrete and the appropriate reinforcing materials. The tanks must also be properly installed.

If you have any questions, please contact me.

Sincerely,

Gary L. Hagy
Assistant Director
Division of Onsite Sewage
and Water Services

Attachment

GMP #26
Onsite - Product Approvals - Septic Tanks