

June 23, 1993

**GMP #31**

**MEMORANDUM**

TO: District Directors  
Environmental Health Managers  
Environmental Health Supervisors  
Environmental Health Project Managers

FROM: David Effert, Technical Services Chief  
Division of Onsite Sewage and Water Services

SUBJECT: Approval for Use of PTI 4" Diameter Double Wall Pipe as  
a Gravity Main in Undisturbed Soil  
Onsite - Product Approval - Pipe

Plastic Tubing Incorporated (PTI) of Roseboro, North Carolina has received approval of its 4" Double Wall Pipe (PTI CORR-A-FLOW®) for use as a gravity main in undisturbed soil under Section 4.22.C of the Sewage Handling and Disposal Regulations.

All appurtances when used with this pipe must comply with Section 4.22.D of the regulations. Plastic Tubing Incorporated does supply compression type joints for connecting the CORR-A-FLOW® to Schedule 40 pipe, and gasketed couplings to connect the pipe to a distribution box. Enclosed is a copy of their product literature. Please note that the PTI CORR-A-FLOW® pipe has not been approved for use as a replacement for Schedule 40 pipe, where Schedule 40 pipe is required.

Enclosure

pc: Cal Sawyer  
Office of Environmental Health Services Staff

**GMP #31**  
**Onsite - Product Approval - Pipe**