

August 18, 1993

GMP #34

MEMORANDUM

TO: District Directors
Environmental Health Managers
Environmental Health Supervisors
Environmental Health Specialists

FROM: David Effert, Technical Services Chief
Division of Onsite Sewage and Water Services

SUBJECT: Approval of PolyLok Pipe Seal
Onsite - Product Approval - Pipe Seals

The Polylok® Pipe Seal as manufactured by United Concrete Products of Yalesville, CT has been approved as a method of eliminating the need to grout pipe to septic tanks and d-boxes. The pipe seal is cast into the septic tank or d-box. Following the manufacturer's instructions, the appropriate knockout is removed depending on the diameter of the pipe being connected. The pipe is then inserted into the pipe seal. The pipe seal is approved for use with 2 inch, 3 inch, and 4 inch diameter smooth wall pipe, and with 4 inch diameter corrugated pipe. A copy of the manufacturer's literature is attached.

Approval of the product does not constitute endorsement for use. Please report any field problems which you may have with the product to me at (804) 786-1750.

DDE/

Attachment

pc: Office of Environmental Health Services Staff
Dr. Cal Sawyer

GMP #34

Onsite - Product Approval - Pipe Seals