

GMP #104

MEMORANDUM

TO: District Directors  
Environmental Health Managers  
Environmental Health Supervisors  
Environmental Health Specialists

FROM: Roger A. Cooley P.E.  
Technical Services Engineer  
Division of Onsite Sewage and Water Services

SUBJECT: Approval of Septic Tank Forms  
Onsite - Product Approval - Septic Tanks

DATE: March 13, 2000

The attached letter is an approval of septic tank forms proposed by Jolin Concrete Industries, Romney, West Virginia. Please add this memo and the attached letter to your GMP Manual as GMP #104.

Attachment

pc: Office of Environmental Health Services Staff

GMP #104  
Onsite - Product Approval - Septic Tanks

March 13, 2000

Mr. Joe H. Frye, President  
Jolin Concrete Industries  
P.O. Box 2050  
Romney, West Virginia 26757

Dear Mr. Frye:

I have reviewed the plans for septic tank forms CP001076, CP001077, and CP001079. Plan CP001076 is for a 1000 gallon tank, plan CP001077 is for a 1500 gallon two compartment tank and CP001079 is for a 1500 gallon tank. The plans appear to substantially comply with the minimum requirements of the Sewage Handling and Disposal Regulations. The 1000 gallon compartment of CP001077 also appears to comply with the regulations. This would allow the 500 gallon compartment of this tank to be used as a pump tank.

Also, please note that this is an approval of the forms only. You still must use a proper material, i.e., a minimum of 3,000 psi concrete and the appropriate reinforcing materials. The tanks must also be properly installed and have inlet and outlet baffles/tees which comply with the regulations.

If you have any questions, please contact me.

Sincerely,

Roger A. Cooley, P.E.  
Technical Services Engineer  
Office of Environmental Health Services