



COMMONWEALTH of VIRGINIA

Department of Health

P O BOX 2448

Richmond, VA 23218

Marissa Levine, MD, MPH, FAAFP
State Health Commissioner

TTY 7-1-1 OR
1-800-828-1120

January 31, 2018

Mr. Calvin Locker
Ecological Tanks, Inc.
2247 Hwy 151 N
Downsville, LA 71234
calvinlocker@sbcglobal.net

Dear Mr. Locker:

On January 18, 2018, you requested that the Aqua Safe Model AS1000 be approved for listing under GMP 2016-03 as TL-3 Generally Approved. The basis of the request is that this model is proportional to the other 'AS' models already approved under previous GMP 147. Your submittal included the following information.

- A cover letter dated January 18, 2018.
- A copy of the NSF/ANSI Standard 40 listing showing the Aqua Safe AS1000 unit as approved under that standard and functionally equivalent to the other 'AS' models already approved.

Based on the information provided, the Virginia Department of Health (VDH) will list the Aqua Safe AS1000 unit as Generally Approved under GMP 2016-03, which will allow it to be used as a Generally Approved Treatment Level 3 treatment unit. VDH notes the rated capacity of the unit is 1,000 gallons per day.

If you need additional assistance, please feel free to contact me at (804) 387-1883 or by email at marcia.degen@vdh.virginia.gov.

Sincerely,

A handwritten signature in cursive script that reads 'Marcia J. Degen'.

Marcia J. Degen, Ph.D., P.E.
Technical Services Administrator
Division of Onsite Sewage, Water Services, Environmental
Engineering & Marina Programs

Cc: Lance Gregory, Acting Division Director
Stephen Elgin, Technical Services Engineer