



COMMONWEALTH of VIRGINIA

Department of Health

M. Norman Oliver, MD, MA
State Health Commissioner

PO BOX 2448
RICHMOND, VA 23218

TTY 7-1-1 OR
1-800-828-1120

September 16, 2019

Carl Perry
E-Z Treat Company
P.O. Box 176
Haymarket VA 20168

Dear Mr. Perry:

Recently E-Z Treat Company added a 750 gallon per day wastewater treatment unit to its product list. This model has been evaluated by the National Sanitation Foundation (NSF) and has been determined to be flow proportionally equivalent to the 600 and 1200 gallon per day models listed under NSF Standard 40, 350, and 245. The 750 gallon per day model is now listed on NSF's website under the referenced standards as well.

The Virginia Department of Health (VDH) issued a Treatment Level -3 (TL-3) general approval to E-Z Treat Company on August 5, 2014, for the 600 and 1200 gallon per day models based on field testing of the units in accordance with 12VAC5-613-70. This current approval is found on the VDH website (vdh.virginia.gov/environmental-health/onsite-sewage-water-services-updated) under Guidance/Memorandum/Policy (GMP) 2016-03. Based on the NSF evaluation of the 750 gallon per day model, VDH is hereby extending the Treatment Level-3 (TL-3) general approval to the 750 gallon per day model.

Should you have any questions on this issue or need additional information, please don't hesitate to contact me at 804-387-1883 or by email at Marcia.Degen@vdh.virginia.gov.

Sincerely,

A handwritten signature in black ink that reads "Marcia J. Degen".

Marcia J. Degen, Ph.D., P.E.
Technical Services Manager
Division of Onsite Sewage and Water Services,
Environmental Engineering & Marina Programs

Cc: Lance Gregory, Division Director
Technical Services Staff