

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2018
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 49G046	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 02/16/2017
NAME OF PROVIDER OR SUPPLIER CRI - NORTH RIVERSIDE			STREET ADDRESS, CITY, STATE, ZIP CODE 2332 NORTH RIVERSIDE DRIVE RICHMOND, VA 23225		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>Description of structure: The facility is a tri level with a construction type of V(000). Sprinkler status: The facility is fully sprinklered with a 13D system.</p> <p>An unannounced Life Safety Code off site paper second revisit to the standard recertification survey conducted on 11/22/16 was conducted on 2/16/17 in accordance with 42 Code of Federal Regulation, Part 483.150 and 410 to 480: Requirements for Intermediate Care Facilities for Persons with Intercrural Deficiency. The facility was surveyed for compliance using the LSC 2012 ICF/IID Existing regulations. The facility was not in compliance with the Requirements for Participation Medicare and Medicaid.</p> <p>Corrected deficiencies are identified on the CMS-2567B.</p>	{K 000}			
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE			TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.