## DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2018 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>			(X3) DATE SURVEY COMPLETED	
		49G028	B. WING			R <b>05/12/2017</b>	
NAME OF PROVIDER OR SUPPLIER				STREET ADDRESS, CITY, STATE	E. ZIP CODE	1 03/	12/2017
TV WILL OF THOUSEN CONTENENT				4213 RESERVOIR ROAD	-,		
CRI RESERVOIR LANE ICF				RICHMOND, VA 23234			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFI TAG	X (EACH CORRECTIVE CROSS-REFERENCE	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS		{K 0	00}			
	Description of structure: One story with a basement with a construction type of V (000) Sprinkler status: The facility is sprinklered using a NFPA 13 R system and the attic is not sprinklered.  An unannounced follow-up survey to the Life Safety Code standard re-certification survey that was conducted on 23 Feb 2017 was conducted on 12 May 2017 in accordance with 42 Code of Federal Regulation, Part 483.150 and 410 to 480: Requirements for Intermediate Care Facilities for Persons with Intellectual Deficiency. The facility was surveyed for compliance using the LSC 2012 ICF/ID Existing regulations. The facility was in compliance with the Requirements for Participation in Medicare and Medicaid.						
LABORATORY	DIRECTOR'S OR PROVIDER/S	SUPPLIER REPRESENTATIVE'S SIGNATUR	RE	TITLE			(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

Facility ID: VAICFMR05