

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 49G039	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN B. WING _____	(X3) DATE SURVEY COMPLETED 05/17/2019
NAME OF PROVIDER OR SUPPLIER FOREST HILLS GROUP HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 3018 FOREST HILL CIRCLE LYNCHBURG, VA 24501		
(X4) ID PREFIX TAG K 000	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG K 000	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>INITIAL COMMENTS</p> <p>Surveyor: 25557</p> <p>Description of Building: The building is a one story wood frame structure with a finished basement. Utilities and administrative offices are located in the basement.</p> <p>Construction Type: V (000)</p> <p>Sprinkler status: The facility is fully sprinklered with NFPA 13 dry pipe system. The system is supplied by municipal water.</p> <p>An unannounced Life Safety Code survey was conducted on 05/17/2019 in accordance with 42 Code of Federal Regulation, Part 483.150 and 410 to 480: Requirements for Intermediate Care Facilities for the Intellectually Disabled. The facility was surveyed for compliance using the LSC 2012 (Existing) regulations. The facility was in compliance with the Requirements for Participation for Medicare and Medicaid.</p>			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.