

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 05/14/2018  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  495384	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01  B. WING _____	(X3) DATE SURVEY COMPLETED  05/08/2018
--	--	---	--

NAME OF PROVIDER OR SUPPLIER <b>FRANCIS MARION MANOR HEALTH &amp; REHAB</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>100 FRANCIS MARION LANE. PO BOX 880 MARION, VA 24354</b>
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	INITIAL COMMENTS  Surveyor: 12589 Description of structure: Three Story Type II (111) brick veneer nursing home with a total of eight smoke compartments Sprinkler status: Fully Sprinklered  An unannounced routine Life Safety Code survey was conducted 05/08/2018 in accordance with 42 Code of Federal Regulation, Part 483: Requirements for Long Term Care Facilities. The facility was surveyed for compliance using the LSC 2012 Existing regulations. The facility was not in compliance with the Requirements for Participation Medicare and Medicaid.  The findings that follow demonstrate non-compliance with Title 42 Code of Regulations, 483.70(a) et seq (life Safety from Fire.)	K 000		
K 920 SS=D	Electrical Equipment - Power Cords and Extens CFR(s): NFPA 101  Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assemblies that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a	K 920		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE <i>Kenneth Rich</i>	TITLE <i>Manager Support Services</i>	(X6) DATE <i>5/16/18</i>
--	--	-----------------------------

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See Instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 05/14/2018  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  495384	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01  B. WING _____	(X3) DATE SURVEY COMPLETED  05/08/2018
NAME OF PROVIDER OR SUPPLIER <b>FRANCIS MARION MANOR HEALTH &amp; REHAB</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>100 FRANCIS MARION LANE. PO BOX 880 MARION, VA 24354</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 920	<p>Continued From page 1</p> <p>substitute for fixed wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4.</p> <p>10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5 This REQUIREMENT is not met as evidenced by:</p> <p>Surveyor: 12589</p> <p>Based on observation and interview, the facility failed to prohibit the use of a flexible cord through a wall or ceiling.</p> <p>The findings include:</p> <p>On May 8, 2018 at 1023 hours, a television monitor mounted to the wall outside of the supply room on the second floor had the power cord extending through the ceiling to outlet above the ceiling. This was confirmed by the Maintenance Director.</p> <p>On May 8, 2018 at 1104 hours, a television monitor mounted to the wall outside of the supply room on the first floor had the power cord extending through the ceiling to outlet above the ceiling. This was confirmed by the Maintenance Director.</p>	K 920	<p><b>PLAN OF CORRECTION</b></p> <p>1) NEW OUTLETS HAVE BEEN INSTALLED BELOW CEILING ON 5/9/18 DOCUMENTED ON WORK ORDER # 44654</p> <p>2) DURING SAFETY ROUNDS ALL AREAS WILL BE CHECKED TO PREVENT ANY FURTHER VIOLATIONS</p> <p>3) INSPECTED FACILITIES STAFF THAT CORDS ABOVE CEILING ARE AGAINST CODES AND WILL CONTINUE TO INSPECT.</p> <p>4) WILL MONITOR BY CONTINUED INSPECT AND SAFETY ROUNDING</p> <p>5) COMPLETION TO BE DONE BY JUNE 15<sup>th</sup></p>	